

**HWSA PFOS/PFOA Sampling Results**

Well No.	Sample Collection Date	PFOS Result (ppt <sup>1</sup> )	PFOA Result (ppt)	Combined PFOS PFOA total concentration (ppt)	Combined PFOS PFOA Health Advisory issued 5/19/16 (ppt <sup>2</sup> )
1	06/24/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
1	12/05/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
1	12/15/2015	6.1	12.0	18.1	70.0
1	05/10/2016	6.8	7.5	14.3	70.0
1	07/27/2016	well out of service for maintenance			70.0
1	08/11/2016	9.2	11.0	20.2	70.0
1	09/22/2016	8.7	12.0	20.7	70.0
1	10/12/2016	8.9	11.0	19.9	70.0
1	10/25/2016	6.3	15.0	21.3	70.0
2	06/25/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
2	12/12/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
2	12/15/2015	16.0	17.0	33.0	70.0
2	05/10/2016	18.0	10.0	28.0	70.0
2	07/27/2016	23.0	14.0	37.0	70.0
2	08/10/2016	27.0	16.0	43.0	70.0
2	09/22/2016	39.0	19.0	58.0	70.0
2	10/12/2016	21.0	16.0	37.0	70.0
2	10/25/2016	20.0	22.0	42.0	70.0
3	12/10/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
3	12/15/2015	3.3	7.4	10.7	70.0
3	05/10/2016	7.0	6.1	13.1	70.0
3	07/27/2016	8.4	6.2	14.6	70.0
3	08/10/2016	11.0	8.4	19.4	70.0
3	09/22/2016	4.9	8.4	13.3	70.0
3	10/12/2016	7.4	8.4	15.8	70.0
3	10/25/2016	4.6	8.8	13.4	70.0
4	06/25/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
4	12/08/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
4	12/15/2015	8.4	9.1	17.5	70.0
4	05/10/2016	10.0	6.3	16.3	70.0
4	07/27/2016	17.0	5.9	22.9	70.0
4	08/10/2016	18.0	9.2	27.2	70.0
4	09/22/2016	13.0	10.0	23.0	70.0
4	10/12/2016	16.0	10.0	26.0	70.0
3	10/25/2016	15.0	8.8	23.8	70.0
7	07/03/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
7	12/12/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
7	12/15/2015	ND <sup>5</sup>	5.0	5.0	70.0
7	05/10/2016	ND <sup>5</sup>	3.1	3.1	70.0
7	07/27/2016	7.7	7.0	14.7	70.0
7	08/10/2016	3.8	8.1	11.9	70.0
7	09/22/2016	5.2	8.9	14.1	70.0
7	10/12/2016	7.8	8.7	16.5	70.0
7	10/25/2016	7.1	7.6	14.7	70.0
9	06/25/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
9	12/12/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
9	12/15/2015	5.7	7.6	13.3	70.0
9	05/10/2016	5.1	4.5	9.6	70.0
9	07/27/2016	8.6	6.8	15.4	70.0
9	08/10/2016	11.0	6.6	17.6	70.0
9	09/22/2016	13.0	11.0	24.0	70.0
9	10/12/2016	14.0	11.0	25.0	70.0
9	10/25/2016	16.0	8.9	24.9	70.0
19	06/24/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
19	12/08/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
19	12/15/2015	6.4	9.2	15.6	70.0
19	05/10/2016	7.8	6.3	14.1	70.0
19	07/27/2016	12.0	7.5	19.5	70.0
19	08/10/2016	14.0	8.6	22.6	70.0
19	09/22/2016	10.0	9.5	19.5	70.0
19	10/12/2016	13.0	9.6	22.6	70.0
19	10/25/2016	10.0	8.4	18.4	70.0
20	06/24/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
20	12/12/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
20	12/15/2015	12.0	14.0	26.0	70.0
20	05/10/2016	11.0	9.0	20.0	70.0
20	07/27/2016	19.0	13.0	32.0	70.0
20	08/10/2016	21.0	14.0	35.0	70.0
20	09/22/2016	17.0	15.0	32.0	70.0
20	10/12/2016	23.0	17.0	40.0	70.0
20	10/25/2016	26.0	20.0	46.0	70.0
22	08/10/2016	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
22	12/08/2014	ND <sup>3</sup>	ND <sup>3</sup>	ND <sup>3</sup>	70.0
22	12/15/2015	8.4	15.0	23.4	70.0
22	05/10/2016	10.0	9.4	19.4	70.0
22	07/27/2016	14.0	12.0	26.0	70.0
22	08/10/2016	15.0	14.0	29.0	70.0
22	09/22/2016	9.1	9.8	18.9	70.0
22	10/12/2016	14.0	14.0	28.0	70.0
22	10/25/2016	14.0	18.0	28.0	70.0

<sup>1</sup> Parts Per Trillion - equivalent to ng/L (nanograms per liter).

<sup>2</sup> The Health Advisory was issued on May 19, 2016 as 70 parts per trillion.

<sup>3</sup> ND - Not Detected - Results below laboratory minimum reporting limit of 40 ppt for PFOS & 20 ppt for PFOA

<sup>4</sup> ND - Not Detected - Results below laboratory minimum reporting limit of 30 ppt for PFOA

<sup>5</sup> ND - Not Detected - Results below laboratory minimum reporting limit of 2.5 ppt for PFOS

<sup>6</sup> ND - Not Detected - Results below laboratory minimum reporting limit of 4 ppt for PFOS

<sup>7</sup> ND - Not Detected - Results below laboratory minimum reporting limit of 2 ppt for PFOA

<sup>8</sup> samples were collected at a distribution site representative of the interconnect

green text indicates EPA UCMR3 compliance sample

