

HWSA PFOS/PFOA Sampling Results

Well No.	Sample Collection Date	PFOS Result (ppt ¹)	PFOA Result (ppt)	Combined PFOS PFOA total concentration (ppt)	Combined PFOS PFOA Health Advisory issued 5/19/16 (ppt ²)	
1	6/24/2014	ND ³	ND ³	ND ³	70.0	
1	12/5/2014	ND ³	ND ³	ND ³	70.0	
1	12/15/2015	6.1	12.0	18.1	70.0	
1	5/10/2016	6.8	7.5	14.3	70.0	
1	7/27/2016	well out of service for maintenance			70.0	
1	8/11/2016	9.2	11.0	20.2	70.0	
1	9/22/2016	8.7	12.0	20.7	70.0	
1	10/12/2016	8.9	11.0	19.9	70.0	
1	10/25/2016	6.3	15.0	21.3	70.0	
1	11/9/2016	9.0	9.6	18.6	70.0	
1	12/1/2016	11.0	12.0	23.0	70.0	
2	6/25/2014	ND ³	ND ³	ND ³	70.0	
2	12/12/2014	ND ³	ND ³	ND ³	70.0	
2	12/15/2015	16.0	17.0	33.0	70.0	
2	5/10/2016	18.0	10.0	28.0	70.0	
2	7/27/2016	23.0	14.0	37.0	70.0	
2	8/10/2016	27.0	16.0	43.0	70.0	
2	9/22/2016	39.0	19.0	58.0	70.0	
2	10/12/2016	21.0	16.0	37.0	70.0	
2	10/25/2016	20.0	22.0	42.0	70.0	
2	11/9/2016	21.0	14.0	35.0	70.0	well suspended from service 11/18/16 as part of short term plan
2	12/1/2016	14.0	9.6	23.6	70.0	well suspended from service 11/18/16 as part of short term plan
3	6/25/2014	ND ³	ND ³	ND ³	0.0	
3	12/10/2014	ND ³	ND ³	ND ³	70.0	
3	12/15/2015	3.3	7.4	10.7	70.0	
3	5/10/2016	7.0	6.1	13.1	70.0	
3	7/27/2016	8.4	6.2	14.6	70.0	
3	8/10/2016	11.0	8.4	19.4	70.0	
3	9/22/2016	4.9	8.4	13.3	70.0	
3	10/12/2016	7.4	8.4	15.8	70.0	
3	10/25/2016	4.6	8.8	13.4	70.0	
3	11/9/2016	7.0	7.0	14.0	70.0	
3	12/1/2016	6.8	7.0	13.8	70.0	
4	6/25/2014	ND ³	ND ³	ND ³	70.0	
4	12/8/2014	ND ³	ND ³	ND ³	70.0	
4	12/15/2015	8.4	9.1	17.5	70.0	
4	5/10/2016	10.0	6.3	16.3	70.0	
4	7/27/2016	17.0	5.9	22.9	70.0	
4	8/10/2016	18.0	9.2	27.2	70.0	
4	9/22/2016	13.0	10.0	23.0	70.0	
4	10/12/2016	16.0	10.0	26.0	70.0	
4	10/25/2016	15.0	8.8	23.8	70.0	
4	11/9/2016	15.0	8.9	23.9	70.0	
4	12/1/2016	14.0	7.5	21.5	70.0	
7	7/3/2014	ND ³	ND ³	ND ³	70.0	
7	12/12/2014	ND ³	ND ³	ND ³	70.0	
7	12/15/2015	ND ⁵	5.0	5.0	70.0	
7	5/10/2016	ND ⁵	3.1	3.1	70.0	
7	7/27/2016	7.7	7.0	14.7	70.0	
7	8/10/2016	3.8	8.1	11.9	70.0	
7	9/22/2016	5.2	8.9	14.1	70.0	
7	10/12/2016	7.8	8.7	16.5	70.0	
7	10/25/2016	7.1	7.6	14.7	70.0	

HWSA PFOS/PFOA Sampling Results

Well No.	Sample Collection Date	PFOS Result (ppt ¹)	PFOA Result (ppt)	Combined PFOS PFOA total concentration (ppt)	Combined PFOS PFOA Health Advisory issued 5/19/16 (ppt ²)
7	11/9/2016	7.4	7.2	14.6	70.0
7	12/1/2016	6.8	6.9	13.7	70.0

HWSA PFOS/PFOA Sampling Results

Well No.	Sample Collection Date	PFOS Result (ppt ¹)	PFOA Result (ppt)	Combined PFOS PFOA total concentration (ppt)	Combined PFOS PFOA Health Advisory issued 5/19/16 (ppt ²)
9	6/25/2014	ND ³	ND ³	ND ³	70.0
9	12/12/2014	ND ³	ND ³	ND ³	70.0
9	12/15/2015	5.7	7.6	13.3	70.0
9	5/10/2016	5.1	4.5	9.6	70.0
9	7/27/2016	8.6	6.8	15.4	70.0
9	8/10/2016	11.0	6.6	17.6	70.0
9	9/22/2016	13.0	11.0	24.0	70.0
9	10/12/2016	14.0	11.0	25.0	70.0
9	10/25/2016	16.0	8.9	24.9	70.0
9	11/9/2016	14.0	8.8	22.8	70.0
9	12/1/2016	13.0	9.0	22.0	70.0
19	6/24/2014	ND ³	ND ³	ND ³	70.0
19	12/8/2014	ND ³	ND ³	ND ³	70.0
19	12/15/2015	6.4	9.2	15.6	70.0
19	5/10/2016	7.8	6.3	14.1	70.0
19	7/27/2016	12.0	7.5	19.5	70.0
19	8/10/2016	14.0	8.6	22.6	70.0
19	9/22/2016	10.0	9.5	19.5	70.0
19	10/12/2016	13.0	9.6	22.6	70.0
19	10/25/2016	10.0	8.4	18.4	70.0
19	11/9/2016	12.0	9.0	21.0	70.0
19	12/1/2016	12.0	7.7	19.7	70.0
20	6/24/2014	ND ³	ND ³	ND ³	70.0
20	12/12/2014	ND ³	ND ³	ND ³	70.0
20	12/15/2015	12.0	14.0	26.0	70.0
20	5/10/2016	11.0	9.0	20.0	70.0
20	7/27/2016	19.0	13.0	32.0	70.0
20	8/10/2016	21.0	14.0	35.0	70.0
20	9/22/2016	17.0	15.0	32.0	70.0
20	10/12/2016	23.0	17.0	40.0	70.0
20	10/25/2016	26.0	20.0	46.0	70.0
20	11/9/2016	27.0	16.0	43.0	70.0
20	12/1/2016	24.0	15.0	39.0	70.0
22	7/24/2014	ND ³	ND ³	ND ³	70.0
22	12/8/2014	ND ³	ND ³	ND ³	70.0
22	12/15/2015	8.4	15.0	23.4	70.0
22	5/10/2016	10.0	9.4	19.4	70.0
22	7/27/2016	14.0	12.0	26.0	70.0
22	8/10/2016	15.0	14.0	29.0	70.0
22	9/22/2016	9.1	9.8	18.9	70.0
22	10/12/2016	14.0	14.0	28.0	70.0
22	10/25/2016	14.0	18.0	28.0	70.0
22	11/9/2016	15.0	20.0	28.0	70.0
22	12/1/2016	13.0	11.0	28.0	70.0

well suspended from service 12/15/16 as part of short term plan

¹ Parts Per Trillion - equivalent to ng/L (nanograms per liter).

² The Health Advisory was issued on May 19, 2016 as 70 parts per trillion.

³ ND - Not Detected - Results below laboratory minimum reporting limit of 40 ppt for PFOS & 20 ppt for PFOA

⁴ ND - Not Detected - Results below laboratory minimum reporting limit of 30 ppt for PFOA

⁵ ND - Not Detected - Results below laboratory minimum reporting limit of 2.5 ppt for PFOS

⁶ ND - Not Detected - Results below laboratory minimum reporting limit of 4 ppt for PFOS

⁷ ND - Not Detected - Results below laboratory minimum reporting limit of 2 ppt for PFOA

⁸ samples were collected at a distribution site representative of the interconnect